



PRASAR BHARATI
(INDIA'S PUBLIC SERVICE BROADCASTER)
OFFICE OF THE EXECUTIVE ENGINEER (ELECTRICAL)
CIVIL CONSTRUCTION WING : ALL INDIA RADIO
SECOND FLOOR : CIVIL LINES : NAGPUR – 440001

e-mail : eeecwairngp@gmail.com

Phone / Fax : 0712 2565839

No. 03/EEE/NGP/DRG/36/2020-21/ 572

Date : 11-02-2021

NOTICE INVITING QUOTATION

The Executive Engineer (Electrical), Civil Construction Wing, All India Radio, Civil Lines, Nagpur -440001 invite sealed quotations on behalf of President of India from approved and eligible contractors of CPWD and those on appropriate list of department of Post / BSNL / MTNL / MES / Railways / Madhya Pradesh / Chhattisgarh state PWD up to 13.00 P.M. on 19-02-2021. The quotations will be opened on same day at 14.00 P.M. in presence of agency / their authorized representatives. In case this happens to be the Government Holiday, it will be opened on the next working day at the same time.

Name of Work : Providing of Surge Protection Device at L.T. Panel for All India Radio, Ambikapur.

S. No.	Description of Item	Quantity	Unit	Rate	Amount
As per schedule of work attached					

Total ₹

Terms & Conditions of work:-

1. Work is to be carried out as per CPWD specifications.
 2. No T & P will be issued by the Department.
 3. Payment shall be made only after completion of work from the office of EE (E), CCW, AIR, Nagpur.
 4. Rate quoted should be inclusive of all the taxes like GST etc.
 5. Time to complete the work will be One (1) Month from the date of issue of work order.
 6. The quotations may be obtained from this office between working hours.
 7. The Earnest Money Deposit of ₹ 2,726/- in form of Treasury Challan / Demand Draft / Pay Order or Banker's Cheque / Deposit at Call Receipt / Fixed Deposit Receipt / Bank Guarantee of any Scheduled Bank is to be submitted along with quotation. The agency should submit Enlistment Document. Price bid of only those bidders would be opened whose EMD and Enlistment are in order. The agency should enclose the bid in two envelopes; one envelope should contain Enlistment document and EMD. The other envelope should contain the price bid super scribing the same in envelope. Both these envelopes should be enclosed in the main outer envelope.
 8. After completion of work, agency has to submit all the test certificates, manual and guarantee / warrantee of manufacturer to the department.
 9. The agency should submit their GSTIN No.
 10. Contractor will comply with all the provision of GST i/c giving the benefit of input Tax credit as per GST conditions applicable.
 11. The GST No. of All India Radio, Chhattisgarh State is 22AAAJP0288R2ZO
- The N.I.Q. may also be seen at website www.allindiaradio.org

Executive Engineer (Electrical)

Copy to:-

1. The Deputy Director General (Engg), 6th floor, New Broadcasting House, Parliament Street, New Delhi for publishing the NIQ on AIR website (e-mail)
2. The Assistant Engineer (Electrical), CCW, AIR, Nagpur.
3. Notice Board / Work File no.17.

Executive Engineer (Electrical)


o/c
8/2/21

SCHEDULE OF WORK

Name of Work : Providing of Surge Protection Device at L.T. Panel for All India Radio, Ambikapur.

S.No.	Description of Item	Quantity	Unit	Rate	Amount
1	Supplying, Installation, Testing and Commissioning of box of size 300mm x 300mm x 170mm Thermoplastic junction Box on the existing wall including connection, interconnection with suitable size copper wire, brass connector strip, earthing etc. including supplying and fixing the following accessories etc. as required. (Make : Hensel Cat.No. Mi0200 or similar superior make as approved by Department) (To be Installed at Studio Site 1 No. & Transmitter Site 1 No.) a) Four Pole 125 Amp. 415 V 10 kA MCCB with Thermal-Magnetic Release Ics=100% of Icu (Make : L&T Type DY 125U Cat.No. EM909840OLO Or similar superior make) -1 No. b) Surge Protection Device Three Phase Four Pole confirming to UL 1449 3rd edition, IEC-61643-1 with neema 1 Degree of protection - 1 Set (Make : ABB Cat.No. 5SD74641, Siemens or any other make as approved by Department)	2 Job	Job		
2	Earthing with G.I. earth plate 600 mm X 600 mm X 6 mm thick including accessories and providing masonry enclosure with cover plate having locking arrangement and watering pipe of 2.7 metre long etc. with charcoal / coke and salt as required.	4 Set	Set		
3	Providing and fixing 25 mm X 5 mm G.I. strip on surface or in recess for connections etc. as required.	10 Mtr	Metre		
4	Providing and fixing 25 mm X 5 mm G.I. strip in 40 mm dia G.I. pipe from earth electrode including connection with G.I. nut, bolt, spring, washer excavation and re-filling etc. as required.	40 Mtr	Metre		
5	Supplying and laying 25 mm X 5 mm G.I. strip at 0.50 metre below ground as strip earth electrode, including connection / terminating with G.I. nut, bolt, spring, washer etc. as required. (Joining shall be done by overlapping and with 2 set of G.I. nutbolt & spring washer spaced at 50mm)	10 Mtr	Metre		
6	Supplying & Laying of one number PVC insulated and PVC sheathed / XLPE power UG cable of 1.1 KV grade of following size in the existing masonry open duct as required.				
a)	3½ X 70 sq.mm	10 Mtr	Metre		
7	Supplying and making end termination with brass compression gland and aluminium lugs for following size of PVC insulated and PVC sheathed / XLPE aluminium conductor cable of 1.1 KV grade as required.				
a)	3½ X 70 sq.mm	4 No.	Each		
TOTAL :					

Contractor's signature with seal


Executive Engineer (Elect.)