SCOPE OF WORK

The Scope Of work For Comprehensive Annual Maintenance contract of 250 Ton Chillers of following Make with VFD Qty-03 Nos.

Details of Chiller

Make	M/s Voltas Ltd- QTY -2Nos	M/s Daikin Air Conditioning India PVT Ltd- QTY -1 no.
Model	ACEGWFXVXR2501MCP2	PFS245-1DBRYV
Туре	Flooded	Flooded
Sr. No	D000014 & D000015	0000101
Capacity	250 TR	237.4 TR
Compressor make and Model	HANBELL/Screw Compressor VLX 830	Mono screw Daikin
VFD Make	Schneider Electric	Danfoss
Date of commissioning	March 2018	March 2017

- 1. Any failure in the VFD panel including all hardware PCBs Display board, semiconductor Fuses and Electrical work etc (VFD Panel as a whole unit) to be repaired/replaced within a 15days.
- 2. Failure of compressor and motor as a whole unit to be repaired/replaced within 15 days.
- 3. All peripheral spares in the chiller system to be replaced/repaired within 15 days.
- 4. Checking lubrication oil for discoloration or contamination and the top up or replacement if required full quantity of lubrication oil to be supplied and filled as and when required.
- 5. Check through liquid sight glasses to determine for refrigerant, full quantity of Gas including supply and Filling as and when required).
- 6. Inspecting the unit for leaks with a soap solution.
- 7. Inspect entire system for any unusual condition such as noise vibration etc.
- 8. Check the system operating pressure and temperature to ensure proper operating conditions.
- 9. Check evaporator and condenser working temperature/condition if any regarding scaling effects.
- 10. Check chilled water flow by checking pressure draw across the chiller.
- 11. Compare the chilled water temperature at full load with the chilled water temperature control Compare the condenser water flow is it as per the set value.
- 12. Inspect all safety controls and electrical controls in VFD adjust if required.
- 13. VFD cubical (panel to be open every quarter cycle and all electrical terminations to be tightened and any abnormality to be rectified / reported to be open the compressor panel and check all electrical terminations and Hardware/software PCB panel and microprocessor if required including supply installation testing and commission of spares / repair complete.
- 14. Inspect all operating control and sequence of operation.
- 15. Descaling of condenser by manual brushing of tubes once in period of contract.
- 16. Descaling of evaporator by manual brushing of tubes once in period of contract.
- 17. Review daily operating log maintained by operating personal / status in software and advise any operation improvement to operating Engineer Report in writing on any detected deficiencies.
- 18. Check the motor insulation and terminations and if required tightened yearly adjustments of controls if required.
- 19. Oil flow switch/ Solenoid valves, etc in the system if needed to be supplied and replaced
- 20. Water Flow switch (evaporator and condenser) etc in the system if needed to be supplied and replaced.
- 21. High pressure and low pressure cut-outs if any needed to be supplied and replaced.
- 22. Thermostatic expansion valve which controls liquid flow to compressor.
- 23. Any breakdown call to be attended for maintenance and repair work during regular working hours, 7Days per week, Holidays and weekend accepted.
- 24. Optimum working performance of chiller in all seasons (summer, monsoon, winter) to be monitor and to be documented for future..
- 25. Ensure availability of Required Software and genuine spares, testing equipments, etc of Voltas and Daikin chiller of 250 Ton.

 Note: Any Break down the complete chiller system to be put through within 15 days. Any delay in repair will be charged on the basis of 0.5% per week AMC cost as penalty.

NOTE: Bidders are Requested to visit the site and go through the centralised Air conditioning water cooled plant and its associated parts before quoting/participating.

हेमतं कुमार देसाई HEMANTH KUMAR DESAI उप निदेशक (अभि.) Deputy Director (Engg.) दूरदर्शन केंद्र, मुंबई

Doordarshan Kendra, Mumbai