


Specification for dismantling of in circuit AC Units & SITC of AC Package units, for seeking Budgetary Quotes from OEMs/Authorised dealers

Doordarshan Kendra, J C Nagara, Bengaluru-560006, seeks Budgetary quotes from OEMs or their Authorised dealers for Supply, Installation, Testing & Commissioning of AC package units at this office, as per the detailed specification given below:

1. The proposal is for Replacement of in circuit Indoor & Outdoor AC units of 6 X 8.3 TR capacity, of Studio-1 & for **Installation of Indoor & outdoor AC units** for cooling of Studio-1 area. The proposed **SITC of AC units should be of rating between 8 TR to 9 TR** and the existing duct arrangement & power distribution panel is to be utilized.
2. The size of the Studio-1 is **371 sq.m.**
3. The Budgetary quote should include rates for dismantling the existing Indoor & outdoor AC units of Studio-1, supply & installation of all the major/minor equipments/units that are required for making the package unit operational and any associated civil/electrical/mechanical work should be taken into consideration and quote to be submitted accordingly.
4. Bidders may visit the Kendra, to assess the existing arrangement and quotes may be submitted after assessing the site requirement(s).
5. The budgetary quotes may be submitted on or before 05.07.2025 by email to sgeddkbg@gmail.com or by post to

The Deputy Director General (Engg.)
Doordarshan Kendra
J C Nagar
Bengaluru-560006

6. For any clarifications in this regard, Sri. L. Gururajan, AD(E) may be contacted on 9962781051.


एस. चिन्नसामी/S. Chinnasami
निदेशक (अभि.)/Director (E)
दूरदर्शन केंद्र/Doordarshan Kendra
बेंगलूरु/Bengaluru - 560 006