

Scope of Work:: Packaged(15*4)Ton AC Plant
Maintenance repairing , replacement and other associated
works at DDK Gwalior. associated work as follows (5 ton*3)in
one unit , total 4 units

I. Servicing of 4 package units and descaling of 15*4 ton
central AC plant.

II. checking of Electric wiring , Relay , contactor , tag block and
defective are replaced.

III. Checking of compressor cooling and Top up of gas. Repair the
defectives/replace

IV. Overhauling of 2 nos.10HP 3 phase motor and
preparation of two nos . base for motor
(size W*L*H=2feet*1.5feet*6inch).

V. Replacement of 5 inch 60 feet inlet and outlet pipe of cooling
Tower. preparation of cooling tower base(size 8*5feet), and cooling
tower water tank base floor repair/ replace (size 6*5*1 feet)

VI. preparation of Two Nos .base of water tank(size 5feet*6.5feet).
VII.Replacement of Honey comb pad of cooling tower
(size 6.5*5.5*5feet) two Nos.

VIII . Replacement of iron/brass valve , 4 nos 5 inch gate valve,
2 nos. 2 inch drain valve and
1inch valve 2 nos

IX All rates should be with fitting charges


10/10/25

सहायक निदेशक (अभि)
दूरदर्शन ग्वालियर