

Doordarshan Kendra, Bengaluru is seeking Budgetary Quotes from OEMs or their Authorised Dealers for SITC of installing 10 x 8.5 TR AC package units for at DDK, Bengaluru (5 nos. for MSR & 5 nos. for ENG section) on or before 16.09.2026

1. Dismantling & safe keeping of existing 10 X 8.3 TR AC package units i.e, outdoor units only, 5 outdoor units pertaining to MSR section & 5 outdoor units pertaining to ENG section. After installation of new outdoor units, associated leak testing of pipelines with nitrogen & filling of Refrigerant to be taken up.
2. Only OEMs or their authorized dealers are to participate in the bidding process. Authorised dealers should invariably submit the OEM authorization certificate along with the bid document.
3. Supply of 10 X 8.5 TR outdoor units with compressors (Hermetically Sealed Scroll Type) as per IS 10617:2018, compatible with the existing cooling coil (AHU) in 2 different sections.
4. Existing Dry air filters & Expansion valves of both AHUs should be replaced of same specification.
5. If any modification in the copper pipe line routing of existing outdoor units that may be required should be assessed at the time of site visit. (MSR section only)
6. Cooling coil (AHU) should be serviced with appropriate chemical before charging the gas. (MSR section only)
7. The existing Cooling Coil (AHU), duct arrangement & blower has to be utilized, the bidder has to make necessary arrangements (Civil / Mechanical) to ensure proper flow of cooled air into the duct.
8. The outdoor units should be properly mounted at the designated location and any Civil / Mechanical arrangements that are required for mounting the outdoor units may be assessed during bid process.
9. Modifications if any required for the existing power supply distribution arrangements may be examined and any related works may be included in the bid.
10. The bidders are to mandatorily visit the Kendra, to assess the exact requirement of materials required for completion of the said work.
11. Successful bidder should have a service centre in Bangalore and any breakdown to be attended "on call service", with minimum downtime.
12. Our office address is as below:

The Deputy Director General (Engg.)
Doordarshan Kendra
J C Nagar
Bengaluru-560006.

13. For any clarifications in this regard, Sri. L. Gururajan, AD(E) may be contacted on 9962781051 and budgetary quotes may be sent by email to sgeddkbg@gmail.com.